

# Agenda: Off Circuit Tapchangers

- Introductions
- Membership
- Old Minutes
- **Mission-Develop Functional Life Test and Report for De-energized Tap-changers**
- **Reports from Reinhausen, Central Moloney, Quality Switch/Cooper, and others on test results**
- Documents
  - Existing C57.131 Requirements for Load Tapchangers
  - Draft Document IEC 60214
  - P.J.H. Proposed Life Test**
  - PJH Proposed Report**
- Discussion
- Future Work
- Adjourn

# Agenda: Off Circuit Tapchangers

## Meeting Minutes from Porto, Portugal from 10/7/08

**Attendance: 15 members + 8 guests for a total attendance of 23 persons.**

- Last Meeting Minutes discussed. It was pointed out the Silicone Oil promotes most contact corrosion by carrying oxygen and turning into sand. Ester fluid is most stable. Even Tin-Copper contact combination passed thermal life in Natural ester (FR3) when it failed in mineral oil.
- Minutes of the last meeting were approved with one change.
- Central Moloney had tested Tin plated copper- Tin plated copper contact combination. They found it to be stable. They did not record voltage drop across the contacts. Instead they measured at the bushings thus losing some sensitivity. Tin plating increased the contact resistance. The overall resistance should be approximately 60 micro-ohm versus 25 micro ohm for silver-silver. The stability of this combination should be verified. Larry Dix will do it at Quality Switch. It was agreed that the contacts should be preconditioned by moving the moving contact stop to stop twice before testing.
- Contact voltage raises the super temperature – Phil Hopkinson had proposed 130 C oil temperature for thermal life testing and 2 XN current. Deter Donal showed data that had been prepared by Dr. Axel Kraemer where lower oil temperature (115 C) and higher current (4XN vs. 2 XN) for Silver – copper contacts was not acceptable. However, experience showed that it should have been. Axel Kraemer of MR had proposed lower Oil temperature (115 deg. C) and higher current (4X normal) for this test to stay well below the flash point of oil. Phil Hopkinson's Calculations showed that at 3X normal current the super temperature increment over top oil should have been 30 Deg.C but at 4X normal current it would be 84 C higher. This gave an acceleration factor that is too high. Phil will send his analysis to Axel for his review. The correct super temp should have been 155C. This has worked in the past. It was pointed out that 130c oil is dangerously close to the flash point of the oil. Acceleration factor should be 1000 to simulate 30 year life.

# **Working Group for Off-Circuit Tapchangers** **by Philip J. Hopkinson**

## **Mission:**

**Develop Functional Life Test and Report for De-energized tapchangers that recognizes transformer applications**

## **Reference Documents:**

C57.12.00 - General Requirements for Liquid Filled Transformers

C57.12.01 - General Requirements for Dry-Type Transformers

C57.91 - Guide for Loading Mineral Oil Immerse Transformers

C57.96 - Guide for Loading Dry-Type Distribution and Power Transformers

# General requirements for Off-Circuit Tapchangers

Off-circuit tap-changers specified in this standard are for use with liquid filled and air insulated transformers and shall only be operated with the transformer de-energized.\*\*

Since these tap-changers are always used as integral parts of transformers, the current ratings must coordinate with the expectations on the transformer. Transformer loading guides allow up to 2 times rated current for up to ½ hr. daily, dependent on ambient temperature and loss of life considerations. This is consistent with Section 9.2.1 of IEEE Loading Guide C57.91-1995. In addition, cold-load pickup of up to 3 times load is permissible as well as inrush current.

The thermal environment for off-circuit tap-changers is normally in or near the top-oil for liquid-filled transformers. Hence the tap-changer must be designed to operate satisfactorily in this environment. For liquid-filled transformers, the sustained rated liquid temperature shall be assumed to be as follows:

$$T_{oil} = T_{tor} + T_{amb}$$

- Where
- T<sub>oil</sub> is the oil temperature for the tap-changer
  - T<sub>tor</sub> is the top oil rise of the transformer
    - The rated rise occurs at rated steady-state load
    - The maximum rise occurs at the highest allowable overload
  - T<sub>amb</sub> is the outside ambient for the transformer

Insulation System	T <sub>tor</sub>		T <sub>amb</sub>		T <sub>oil</sub>	
	Rated	Max	Rated	Max	Rated	Max
55 C	45	60	20	40	65	100
65 C	55	70	20	40	75	110

Miami, FL, April 21, 2009  
*Note that the 110 Max oil temperature is consistent with Section 9.2.1 of IEEE Loading Guide C57.91-1995*

# Dry Type Tap-changers

Dry type tap-changers can be considered to be of three different styles:

- a. Suitable for mounting above the core-clamp and exposed to air that is heated by the transformer windings
- b. Suitable for mounting within the transformer cabinet but not above the transformer core and windings
- c. Suitable only for mounting in a separate enclosure and not exposed to air that is heated by the windings or core.

Tap-changer air temperatures for the three cases are as follows:

Style	Outside Amb		Rise/Amb		Net Air Temp	
	Rated	Max	Rated	Max	Rated	Rise
a. On Core Clamp	30	40	130	150	160	190
b. In trans. Cabinet	30	40	50	70	80	110
c. Separate Cabinet	30	40	20	30	50	70

## Life Considerations

Life expectancy is commonly addressed in terms of thermal life. Transformer thermal life is assumed to be 20 years. In IEEE's Liquid-filled transformer loading guide (IEEE 57.91-1995), uses 180000 hours at rated load and ambient as the thermal index. Thermal life is a parameter that is both dependent on temperature and material composition. Both insulation and contact deterioration by oxydation have been found to obey the 10°C rule. Under the rule, each 10°C above or below the reference temperature causes life to change by 2 to 1.

## Nameplate/Specified Ratings

Tap-changers shall be rated in terms of the following criteria and other requirements irrespective of the type of construction:

Table 5A-Rated current characteristics of off-circuit tap-changers

Maximum Continuous Rated Current Amps	Maximum Double Current for ½ hr. /Day	Max Symmetric Through-fault Current (amps)	Max Crest Fault Current (amps)
--	---	--	--------------------------------------

Table 5B-Rated voltage characteristics of off-circuit tap-changers

System Highest Voltage	BIL Line- Gnd	Max BIL Tap-Tap	Max BIL Between 2 Tap Positions
------------------------------	---------------------	--------------------	---------------------------------------

# Quality Switch Silver-Silver Rotating Contact Tapchanger Ratings New IEC/IEEE Format

Switch No.	Voltages, (000)				Current Ratings, Amps			
	Highest System Volts	Max. System BIL	Max. BIL Tap-Tap	Max. BIL Tap-2 Taps	Max. Continuous	Max. 2x Rated ½ hr./day	Max. Symm Thru-Fault Current	Max. Crest Fault Current
Single Ring								
70-543-01	25	125	150	132	200	400	5000	7500
70-543-02	35	200	150	132	200	400	5000	7500
70-543-04	45	250	150	132	200	400	5000	7500
Triple Ring								
70-545-02	35	150	150	132	500	1000	14,000	20,000

**New ratings allow users to match transformer application**

## Tapchanger Suitability for Synthetic Insulating Liquids

Synthetic insulating liquids may behave quite differently than mineral oil. Some of the more pronounced differences that have been observed are oxidation-stability, lubricity, heat transfer, dielectric integrity, flammability, and viscosity. Tap-changer ratings for use in synthetic insulating fluids must be established by the manufacturer.

### Stability in Natural Ester Fluid

Natural ester fluid has proven to be stable in testing to date for a wide variety on contact pairs. It is still recommended that manufacturers test any proposed combinations of fluids and contact pairs to develop stability considerations before establishing switch ratings.

# Routine and Type Test Requirements

Test	Routine	Type
a. Contact Resistance	X	
b. Contact spring pressure	X	
c. Dielectric Integrity	X	
d. Functional Life		X
e. Short Circuit		X
f. Mechanical endurance		X
g. Operating torque (manual )		X
h. Gland seal (Vacuum)	X	

# Temperature Rise of Contacts

Tests shall be performed to verify that the temperature rise above the medium surrounding each type of contact, which carries current continuously in service, does not exceed the values given in table 6. This test shall be performed when the contacts have reached a steady temperature when carrying the through-currents in accordance with table 6, with tap-changer ambient in accordance with the rated values in section 7.1. The test is performed by measurements with thermocouples or other devices capable of measuring bulk temperature, and ambient liquid or air. The bulk rise is the difference between the bulk temperature and the temperature of the tap-changer environment ( liquid or air).

It is important to note that the temperature rises in table 6 are limit values. The manufacturer must recognize that stable materials must be used so that aging does not result in thermal runaway. Time shall not result in higher temperature rises at the table 6 currents.

Table 6- Contact temperature-rise for off-circuit tap-changers

Style	Rated Current	2X Rated Current
Liquid	10	30
Dry	25	75

# Functional Life Tests

A functional life test shall be performed as a Type Test to demonstrate the adequacy of the contact design to achieve long stable thermal life. The test consists of thermal cycling at accelerated current and temperature, with daily cool-down cycles. A successful test is completed if contact resistance remains within 25% of the original value and stability is achieved.

**The test is conducted by passing twice rated current through the contacts for 8 hours per cycle at ambient temperatures of 130°C**

**A total of 30 cycles (days) of the 8-hour on 16 hour off 2XN current are required to complete the functional life test.**

## **2 Criteria of success:**

1. Resistance change <25%
2. Stability reached

# Functional Life Tests-Issues


## Issues for test

1. **Connections to tapchanger for current, voltage and temperature**
2. **Oil volume for the test**
3. **Oil temperature**
4. **Current in multiples of rating**

## **2 Criteria of success:**


1. Resistance change  $<25\%$
2. Stability reached

# Functional Life Tests-Connections



**Tapchanger thermocouple and voltage measurements, courtesy of Quality Switch**

# Functional Life Tests-Multiple decks in series



**Hi gh Current Tapchanger (>500 amp rated)  
Connections, courtesy of Quality Switch**

# Functional Life Tests-Issue of Oil Volume

## Large liquid volume important for test validity

1. Most representative of real transformer environment
2. Will contain dissolved gases
3. Provides opportunity for replacement of oxidized liquid
4. Should slow down thermal runaway

**Important to replicate real environment**

# Functional Life Tests-Issue of Oil Volume

## **130 C Liquid Temperature a good selection**

1. Possible in real transformer at 2XN load for ½ hour in 30-40 C ambient.
2. Reflects IEEE C57.91 Loading Guide
3. Provides representative viscosity and activity
4. Provides sufficient acceleration to be reproducible

**Important to replicate real environment**

# Functional Life Tests-Issue of Oil Volume



## **2XN current important to test**

1. Possible in real transformer at 2XN load for ½ hour in 30-40 C ambient.
2. Reflects IEEE C57.91 Loading Guide
3. Provides representative heating and current density.
4. Contact super temperatures respond:
  - Low rise for stable contacts
  - Thermal runaway with oxidation



**Important to replicate real environment**

TABLE 1 Electrical Contact Super Temperature									
	<b>Super Temp =</b>	$\text{SQRT}((T_a+T_o+T_b+273)^2+((A3*0.001)^2)/(4*2.4*10^{-8}))-273$							
	<b>Ta = Ambient</b>	20		20		20		20	
	<b>To = Oil Rise</b>	50		110		110		110	
	<b>Tb = Bulk Rise</b>	20		40		60		20	
	<b>Bulk Temp</b>	90		170		190		150	
Millivolts	Super Rise	Super Temp	Super Rise	Super Temp	Super Rise	Super Temp	Super Rise	Super Temp	Condition
10	1.4	91.4	1.2	171.2	1.1	191.1	1.2	151.2	Good
20	5.7	95.7	4.7	174.7	4.5	194.5	4.9	154.9	
30	12.7	102.7	10.5	180.5	10.0	200.0	10.9	160.9	
40	22.3	112.3	18.4	188.4	17.7	207.7	19.3	169.3	Marginal
50	34.3	124.3	28.5	198.5	27.3	217.3	29.7	179.7	
60	48.4	138.4	40.5	210.5	38.9	228.9	42.2	192.2	
70	64.6	154.6	54.3	224.3	52.2	242.2	56.6	206.6	Unstable
80	82.5	172.5	69.8	239.8	67.1	257.1	72.6	222.6	
90	101.9	191.9	86.7	256.7	83.6	273.6	90.1	240.1	
100	122.7	212.7	105.1	275.1	101.4	291.4	109.1	259.1	
110	144.8	234.8	124.7	294.7	120.4	310.4	129.2	279.2	Thermal Run-A-Way
120	167.8	257.8	145.4	315.4	140.6	330.6	150.5	300.5	
130	191.8	281.8	167.2	337.2	161.8	351.8	172.8	322.8	
140	216.6	306.6	189.8	359.8	183.9	373.9	195.9	345.9	
150	242.1	332.1	213.2	383.2	206.9	396.9	219.9	369.9	
160	268.2	358.2	237.4	407.4	230.6	420.6	244.5	394.5	
170	294.9	384.9	262.2	432.2	254.9	444.9	269.8	419.8	
180	322.0	412.0	287.6	457.6	279.9	469.9	295.6	445.6	
190	349.6	439.6	313.5	483.5	305.4	495.4	322.0	472.0	
200	377.6	467.6	339.9	509.9	331.4	521.4	348.7	498.7	



Results of Life Tests





Voltage is measured between the two mating contacts under test.



Bulk temperature in degrees C is the average temperature of the two mating contacts under test measured by thermocouple



Super temperature is a calculated parameter in degrees C and refers to the temperature of the point of contact of the two mating contacts under test



Contact resistance is measured by dividing the contact voltage under test by the test current


## Assessment Time De-energized Tapchangers

### New Work at Quality Switch

- Contacts: Tin plated copper versus plain copper
- FR3 Natural Ester Fluid
- 30 day test
- Status report after 16 days on test

Similar tapchangers in silicone and mineral oil unstable at first day on test.

# Assessment Time De-energized Tapchangers



**Similar tapchangers in silicone and mineral oil unstable at first day on test.**

## Assessment Time De-energized Tapchangers

### Completed Work

- Functional Life Test Defined
- (3) Manufacturers have performed test
- **Test correlates with Harsh Duty field experience- switches that pass do well.** Example transformers – rolling mills

**Limitation: General Purpose Transformers with light duty work OK with unstable contacts**

## Assessment Time De-energized Tapchangers

### Completed Work-2

- Draft Technical Report issued

**Limitation:** To date: Only two authors on paper

## Assessment Time De-energized Tapchangers

### Derivation-oil temperature versus current

- Basic relationships
- Super temperature = Oil temp + bulk temp + super/bulk
- Hold super temp constant:

<b>For Stable Silver-Silver Contacts</b>		<b>Avg of Method 1 and 2</b>		
<b>Current, times normal</b>		<b>2</b>	<b>3</b>	<b>4</b>
Tbulk rise		18	35	55
T super rise over bulk		3	7	12
T super + bulk		21	42	67
Tgoal		151	151	151
Toil		130	110	84
<b>Case</b>		<b>Base</b>	<b>Alt1</b>	<b>Alt2</b>

**Conclusions; Alternative currents and oil temperatures should work and give consistent results**

# Assessment Time De-energized Tapchangers

## Derivation-oil temperature versus current

$$T \text{ super} = T \text{ oil} + T \text{ bulk/oil} + T \text{ super rise/bulk}$$

T Bulk/oil at rated current = 6

Current XN	Toil	T Bulk/oil	Toil+Tb/oil	Tbulk'	V	Method 1		
						Tsuper/Tbulk	Tbulk + Tsuper/bulk	
1	144	6	1	6	0.008	1	7	
2	130	18	1	18	0.016	3	21	
3	110	35	1	35	0.024	7	42	
4	84	55	1	55	0.032	12	67	
Difference between 4XN and 2XN								46

Method 1				
Current, times normal		2	3	4
Tbulk rise		18	35	55
T super rise over bulk		3	7	12
T super + bulk		21	42	67
Super Temperature = Tgoal		151	151	151
Toil		130	110	84
Case		Base	Alt1	Alt 2

Contacts	Super Temp, C
Silver-Silver	151
Copper-Copper	167
Tin-Copper	163
Ag-Ni	223

**Conclusions; Alternative currents and oil temperatures should work and give consistent results**

## Assessment Time De-energized Tapchangers

### Remaining Work

- Modified tests for other currents and bath temperatures
- Unified definition of the Functional Life Test
- Agree on Technical Paper
- Transmit materials for inclusion in C57.131

## Assessment Time De-energized Tapchangers

### Recommendations

- Stop data Quest in 1 more meeting at **Fall 2009**
- Freeze test at present definition  
**Completed now**
- Agree on Technical Paper **Fall 2009**
- Transmit materials for inclusion in C57.131  
**Spring 2010**